

N 7 2 - 2 5 0 2 2

**NASA TECHNICAL  
MEMORANDUM**

**NASA TM X-68054**

**NASA TM X-68054**

**CASE FILE  
COPY**

**COST STUDY OF SOLAR CELL  
SPACE POWER SYSTEMS**

by Daniel T. Bernatowicz  
Lewis Research Center  
Cleveland, Ohio

**TECHNICAL PAPER** proposed for presentation at  
Ninth Photovoltaic Specialists Conference sponsored  
by the Institute of Electrical and Electronics Engineers  
Silver Spring, Maryland, May 2-4, 1972

E-6904

Lewis Research Center  
National Aeronautics and Space Administration  
Cleveland, Ohio

A study of historical costs for solar cell space power systems was made by a NASA ad hoc study group. The study covered thirteen missions that represented a broad cross-section of flight projects over the past decade. Fully burdened costs in terms of 1971 dollars are presented for the system and the solar array. The costs correlate reasonably well with array area and do not increase in proportion to array area. The trends for array costs support the contention that solar cell and module standardization would reduce costs.

In 1971 a study was made of solar cell space power systems for NARA-OART. The study was performed by an NASA ad hoc group consisting of the author; Anthony T. Diamond, NASA-HQ; John Goldsmith, JPL; Charles M. MacKenzie, GSFC; Jimmy Miller, MSFC; and John Toma, LeRC. The study group looked at the solar power systems for thirteen missions that represented a broad cross-section of flight projects over the past decade. These covered a range in average output from less than 100 watts to 4 kw. They included body-mounted and oriented arrays, a variety of orbits and trajectories, and a variety of sponsors and contractors. Actual accrued costs or estimated costs to completion for projects in progress were obtained at a level considerably more detailed than presented in this paper. The detailed costs were reconstructed by the study group in as consistent a manner as possible to allow comparisons among projects. The costs were broken down into recurring and non-recurring costs for the solar array, battery, and power conditioning. Costs for orientation and development subsystems were not included. The study could not be made with the thoroughness or accuracy of an audit; often assumptions had to be made about burden rates and allocations of costs to subsystems. The results are presented as estimates of the costs of the systems and are not to be taken as exact figures. The results are presented as estimates of the costs of the systems and are not to be taken as exact figures. The results are presented as estimates of the costs of the systems and are not to be taken as exact figures.

It has been common to discuss power system costs in terms of dollar-per-kw, implying that costs correlate best with power usage in this system. It has been common to discuss power system costs in terms of median power and average system power, rather than to be poor. However, this study shows that power system costs correlate reasonably well with array area. Not surprisingly, considerable scatter remained.

[illegible]


show considerable scatter. The straight line shown was fit to make this correlation consistent with the solar array cost index and unit recurring cost. Figure 6 shows the unit recurring cost for the solar array. Here again the cost does not rise in proportion to array area. The unit recurring cost is about \$0.7 M at 100 sq ft and \$4 M at 1000 sq ft.

All these trends indicate the costs do not rise in proportion to the size of the system. This is due in part to the relatively fixed non-recurring costs. But the increase in recurring costs is also slow. For the array this trend suggests that there is significant cost reduction due to volume of production. This cost reduction would depend not only on the size of the array, but also on the number of arrays built. Figure 7 shows the solar array recurring cost per square foot plotted against the total area of flight arrays built for each project. Figure 7 shows a somewhat better correlation than figure 6. It also shows a stronger effect of area on cost reduction. The cost decreases from \$10,000/sq ft for 100 sq ft to \$4500/sq ft for 1000 sq ft to \$3000/sq ft at 3000 sq ft. Figure 7 illustrates the gains in productivity as a team gains experience with repetitive operations. It strongly supports the opinion long-held in the solar array community that more standardization would reduce costs. Standardized cells or modules would allow the costs per square foot for the smaller programs to drop and approach the costs now possible only for the large programs.


#### CONCLUSIONS

This study of historical costs of solar cell power systems showed that cost per kw. is not a useful parameter to characterize the system costs. System and array costs correlated reasonably well with array area. However, the costs did not rise as fast as array size. The trend for the array of reduced recurring cost per square foot as more array area is built for a project strongly supports the claim that solar cell and module standardization would reduce costs.


#### SOLAR POWER SYSTEM TOTAL COST INDEX NONRECURRING COST + 2 UNIT RECURRING COST




#### SYSTEM NON-RECURRING COST




#### SYSTEM UNIT RECURRING COST




#### SOLAR ARRAY TOTAL COST INDEX NONRECURRING COST + 2 UNIT RECURRING COST



### SOLAR ARRAY NON-RECURRING COST



### SOLAR ARRAY UNIT RECURRING COST



### SOLAR ARRAY RECURRING COST PER SQUARE FOOT

